

**Schedule G**  
**Proposed Conditions**

**Enbridge Gas New Brunswick  
Construction Application for Dorchester, New Brunswick**

**Conditions**

1. Subject to Condition (3), Enbridge Gas New Brunswick (EGNB) shall comply with all undertakings made by its counsel and witnesses, and shall construct the facilities and shall restore the land according to the evidence of its witnesses at this hearing and in accordance with the Gas Distribution Act, 1999, the Pipeline Act, 2005 or any other applicable legislation.
2. EGNB shall comply with all written commitments and clarifications made during review by the Pipeline Coordinating Committee (PCC).
3. The Board's designated representative for the purpose of these conditions shall be the Director of Safety, or in his/her absence, the Board's secretary. EGNB shall advise the Board's designated representative of any proposed significant change in construction or restoration procedures, and except in an emergency, EGNB shall not make such change without prior approval of the Board or its designated representative. In the event of an emergency, the Board shall be informed forthwith.
4. EGNB shall furnish the Board's designated representative with every reasonable facility for ascertaining whether the work has been, and is being, performed in accordance with the Board's Order.
5. EGNB shall notify the Board's designated representative of the date on which any installed high pressure and extra-high pressure pipeline is proposed to be pressure tested at least 72 hours prior to the start of the test.
6. Both during and after construction, EGNB shall monitor the effects upon the land and the environment.
7. EGNB shall give the Board's designated representative and the Chairman of the PCC 10 days' written notice, in advance of the commencement of construction, unless said construction is to commence within 10 days of receipt of the Board's decision and in such an event shall be as soon as possible.
8. In the case of infill, EGNB shall file written notification in the approved format to the Board's designated representative of the pending construction of high and extra high-pressure steel and high-pressure polyethylene pipelines.

9. EGNB shall designate one of its employees as project manager who will be responsible for the fulfillment of undertakings on the construction site and shall provide the name of the project manager to the Board's designated representative.
10. Where properties or structures exist within 200 metres of the pipeline and blasting is necessary, EGNB shall:
  - (a) use restricted blasting techniques by ensuring that all charged areas are covered with blasting mats to eliminate flying rocks;
  - (b) have the vibrations from blasting operations monitored and measured by a vibration measurement specialist;
  - (c) notify all property owners within 200 metres of the proposed blasting in writing at least 24 hours prior to the blasting and confirmation (if necessary) of the actual day or days on which blasting will occur;
  - (d) have buildings within 200 metres of the blasting checked by an independent examiner before and after operations to check for problem areas.
11. A proposal for a Site-Specific Baseline Water Quality Survey must be submitted to the Department of Environment for private wells within 500 m of blasting activities. The proposed Survey must be approved by Department of Environment (DENV) and implemented prior to the start of any construction activities related to the project.
12. EGNB must immediately notify the DENV Moncton Regional Office (506 856-2374) of any complaints received regarding water quantity or quality problems.
13. In the event that domestic wells are impacted, EGNB shall provide a water supply to the homeowners until the problem is resolved. This includes, but is not limited to, the provision of potable water and the remediation or replacement of any impacted domestic wells. If an agreement as to the cause of the water problems cannot be reached between EGNB and the resident(s), the DENV will provide third party arbitration.
14. No fueling of vehicles or storage of petroleum products shall occur within 30 metres of any domestic wells.
15. Any abandoned wells found during this project will be reported to the Moncton Regional Water Planning Officer.
16. EGNB shall assess all pipeline construction routes with respect to environmental requirements and develop Site Specific Environmental Protection Plans as required, including for wetlands. EGNB shall obtain all required environmental permits.

17. EGNB shall monitor Total Suspended Solids (TSS) and take appropriate corrective action where appropriate.
18. EGNB shall take immediate corrective action upon being notified of deficiencies in environmental protection measures by an environmental inspector (from any agency).
19. EGNB shall conduct appropriate surveys for species of special status unless it is clear that the method of construction will have no potential impact on the critical habitat for these species.
20. In the event of construction through identified wetlands, EGNB shall ensure monitoring of wetland mitigation is conducted as part of the Environmental Effects Monitoring (EEM) program that includes at least one year of monitoring post-construction unless additional follow-up monitoring is required. The EEM program for wetlands shall not be limited to TSS monitoring.
21. Unless the Board otherwise directs, EGNB shall maintain at its Fredericton office, copies of any permits, approvals or authorizations for the applied-for facilities issued by federal, provincial and other permitting agencies, which include environmental conditions or site-specific mitigative, monitoring and restorative measures. In addition, EGNB shall maintain at its Fredericton office, an information file(s) that would include any subsequent variations to any permits, approvals or authorizations obtained prior to, or following, the commencement of construction.
22. Unless the Board otherwise directs, EGNB shall maintain for audit purposes, at its Fredericton office, a copy of the joining procedures and non-destructive testing procedures used on the project, together with all supporting documentation.
23. In areas of acid rock, EGNB shall comply with the Acid Rock Drainage Mitigation Program developed by EGNB.
24. As the preferred crossing option at all crossings, EGNB shall avoid in-stream work. Any departure from this approach will require the provision of an adequate rationale to the DOE.
25. Unless the Board otherwise directs, EGNB shall submit semi-monthly construction reports during the construction season for systems to be constructed under this permit and such other reports as requested by the Department of Energy from time to time.
26. EGNB shall submit its Emergency Procedures Manual to the Emergency Measures Organization for review prior to filing an application for a Licence to Operate the proposed facilities.
27. EGNB shall submit the construction details of any custody transfer station to the Board prior to the start of construction.

28. EGNB shall submit design details and specifications for any boiler and pressure vessels to the Manager, Gas Inspections of the Technical Inspection Services branch of Public Safety for review prior to construction.
29. EGNB shall ensure that the pipeline alignment remains within 1 - 2 metres of the Right-of-Way of Woodlawn Avenue and King Street outside the municipal limits of the Village of Dorchester and Town of Sackville.
30. EGNB shall file with the Board the executed Municipal Operating Agreement prior to the start of any construction within the municipal limits of the Village of Dorchester.
31. Within six months of the in-service date, EGNB shall file with the Board a written Post Construction Financial Report. The Report shall indicate actual capital costs of the project and shall explain all significant variances from the estimates adduced in the hearing.